Q QT612

QUANTEC RELAY OUTPUT DEVICE

The QT612 provides a zone-specific relay output that can be used to trigger third-party strobes, sounders, auto-diallers, etc . Please refer to the help files embedded within the software supplied with our QT423 configurator for detailed programming and installation instructions.

FIGURE 1 : Typical wiring scenario for the QT612 relay ouput device

Network Connections

Diagnostic Green LED
On when Relay is Active
Flashing when Unassigned
Call is pending

1 — Net-
2 — Net-
3 — Net+
4 — Net+
5
6 — Link momentarily to clear Device Address
7 — Linkmomentarily to make Unassigned Call
8
9
10 — N/C Relay Contact
11 — N/O Relay Contact
12 — Common Relay Contact

Note:
Relay Contact Rating
30V 1A Maximum

Configuration
Programming
Connector